

POLYREY
700 route de Bergerac
D660
24150 BANEUIL
FRANCE

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com/VOC-testing

RAPPORT D'ESSAI D'ÉMISSION DE VOC


Indoor Air Comfort GOLD[®]

16 mars 2020

1 Informations relatives à l'échantillon

Nom de l'échantillon	Panoprey
Numéro de lot	826562
Date de production	29/05/2019
Type de produit	Paneau
Date de réception	20/06/2019

2 Résumé de l'évaluation des résultats

Réglementation / Protocole	Conclusion	Version de la réglementation ou du protocole
Etiquetage sanitaire français		Décret et arrêté de mars et mai 2011 (DEVL1101903D et DEVL1104875A)
Composés CMR français	Conforme	Décret et arrêté de avril et mai 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM	Conforme	Decree 11 janvier 2017 (GU n.23 del 28-1-2017)
AgBB/ABG	Conforme	Anforderungen an bauliche Anlagen bezüglich des Gesundheitsschutzes (ABG), Entwurf 31.08.2017/Août 2018 (AgBB)
Réglementation belge relative aux émissions de COV	Conforme	Décret royal de mai 2014 (C - 2014 / 24239)
Indoor Air Comfort [®]	Conforme	Indoor Air Comfort 6.0 de février 2017
Indoor Air Comfort GOLD [®]	Non conforme	Indoor Air Comfort GOLD 6.0 de février 2017
Blue Angel (DE-UZ 132)	Non conforme	Low-Emission Thermal Insulation Material and Suspended Ceilings for Use in Buildings, October 2010
BREEAM International	Conforme	BREEAM International New Construction v2.0 (2016)
LEED v4.1	Conforme	LEED v4.1 for Building Design and Construction (Juillet 2019) Beta
BREEAM [®] NOR	Conforme	BREEAM-NOR New Construction v1.2 (2019)

Le détail complet des tests et des valeurs limites est disponible pages suivantes.



Janne Rothmann Norup
Analytical Service Manager

POLYREY
700 route de Bergerac
D660
24150 BANEUIL
FRANCE

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com/VOC-testing

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD[®]

16 August 2019

1 Sample Information

Sample name	Panoprey
Batch no.	826562
Production date	29/05/2019
Product type	Panel
Sample reception	20/06/2019

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Regulation of March and May 2011 (DEVL1101903D and DEVL1104875A)
French CMR components	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM	Pass	Decree 11 January 2017 (GU n.23 del 28-1-2017)
AgBB/ABG	Pass	Anforderungen an bauliche Anlagen bezüglich des Gesundheitsschutzes (ABG), Entwurf 31.08.2017
Belgian Regulation	Pass	Royal decree of May 2015 (C-2014/24239)
Indoor Air Comfort [®]	Pass	Indoor Air Comfort 6.0 of February 2017
Indoor Air Comfort GOLD [®]	Fail	Indoor Air Comfort GOLD 6.0 of February 2017
Blue Angel (RAL UZ 132)	Fail	Low-Emission Thermal Insulation Material and Suspended Ceilings for Use in Buildings, October 2010
BREEAM International	Compliant	GN22 v2.3 (March 2018): BREEAM Recognised Schemes for VOC Emissions from Building Products
LEED v4.1	Compliant	LEED v4.1 for Building Design and Construction (July, 2019, Beta version)
BREEAM [®] NOR	Pass	BREEAM-NOR New Construction v1.1 (May 2017)

Full details based on the testing and direct comparison with limit values are available in the following pages



Janne Rothmann Norup
Analytical Service Manager



Maria Pelle Madsen
Analytical Chemist

The results are only valid for the tested sample(s).

This report may only be copied or reprinted in its entity, parts of it only with a written acceptance by Eurofins.